



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Purulia Fire Station, Ranchi Road, Purulia, Pin:- 723101

Date : 09-11-2024

Memo No.:FSR/0125186237800333

From :
Divisional Fire Officer
Bankura Division,
West Bengal Fire & Emergency Services

To :
SWAMI NIGAMANANDA PUBLIC SCHOOL, OF NIGAM SOCIAL WELFARE AND EDUCATION TRUST
AT LALGARH, DAG RS- 14190,14191,14201 AND 14202, LR 2320123360,23361,23362,23363 AND 23368, NEAR LAL
BANDH, KH NO- 24490, JL NO-101, UNDER BISHNUPUR MUNICIPALITY, MOUZA, BISHNUPUR, BANKURA, PIN-
722121.
Sub : Fire Safety Certificate for an existing occupancy of G+I storied building under group Educational building in
favor of "SWAMI NIGAMANANDA PUBLIC SCHOOL, OF NIGAM SOCIAL WELFARE AND EDUCATION TRUST" at
the premises of LALGARH, DAG RS- 14190,14191,14201 AND 14202, LR 2320123360,23361,23362,23363 AND 23368,
NEAR LAL BANDH, KH NO- 24490, JL NO-101, UNDER BISHNUPUR MUNICIPALITY, MOUZA, BISHNUPUR,
BANKURA, PIN-722121.

This is in reference to your AIN 211892406300002952 dated 27-Oct-2024 regarding Fire Safety Certificate for an existing
occupancy of G+I storied building under group Educational building in favor of "SWAMI NIGAMANANDA PUBLIC SCHOOL,
OF NIGAM SOCIAL WELFARE AND EDUCATION TRUST" at the premises of LALGARH, DAG RS- 14190,14191,14201
AND 14202, LR 2320123360,23361,23362,23363 AND 23368, NEAR LAL BANDH, KH NO- 24490, JL NO-101, UNDER
BISHNUPUR MUNICIPALITY, MOUZA, BISHNUPUR, BANKURA, PIN-722121..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily
working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid
building.

Recommendation:

1. Driveway must be free from any obstruction for easy movement of Fire appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of the building shall be made with low flame spread material conforming to



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the
Verification of Digitally Signed Document link and keying in the Unique Number : 211892406300002952

the I.S. Specification.

3. To eliminate risk of Fire Hazards, Good house keeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any wear and tear them, particularly lines above false ceiling & ducts.
5. The notice of Fire fighting and evacuation from the building shall be prepared and displayed at all vulnerable of the building.
6. The employees and security staff shall be conversant with installed fire fighting equipment of the building and to operate in the event of Fire & testing.
7. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the building.
8. Switch Gear room shall be protected with automatic CO2 fire extinguisher confirming I.S. Specification.
9. A trained fireman shall be maintained round the clock for safety of the building.
10. First Aid Fire Fighting system shall be provided as per I.S. Specification.
11. Arrangement shall have to be made for regular checking, testing and maintenance of all the fire fighting installation in the building to keep them perfectly good working condition at all times.
12. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth
13. Periodical flashing of water in the Hose Reel Hose Pipe line shall be made to maintain the efficiency working performance of above mention system.
14. The fire safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
15. Fire License shall have to be obtained for proposed storing of LPG & other highly combustible article.
16. This Fire Safety Certificate is valid for three years from date of issue & has to be renewed after every three years.

Valid Upto : 08-Nov-2027

Memo No.:FSR/0125186237800333



Signature valid

Digitally Signed.
Name: Debajyoti Barua
Date: 09-Nov-2024 12:34:59
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892406300002952